

Evidence of Performance

Burglar resistance properties

Test Report 10-000206-PB04-A01-05-en-01



Client	Keller AG/SA Route de Wilwerdange 38-40 9991 Troisvierges Luxembourg
Product	Burglar resistance sliding windows with fixed light
Designation	Minimal Windows
Overall dimensions (W x H)	4,021 mm x 2,652 mm
Material, System (Frame)	Aluminium profiles with thermal break, Minimal Windows
Attack side	External face of construction
Type of opening	single leaf, sliding
Glazing	Class A3 acc. to DIN 52290 (Class P4 A acc. to EN 356) two roller Type 25-04-110 of the company Astec – espagnolette lock Type Minimal Windows of the company Astec with aluminium alloy locking bar Ø 8 mm - two inlet sockets Type 25-04-420 of the company Keller - detachable handle Type Minimal Windows of the company Astec
Hardware	According to the installation construction dated July 2010
Installation	of the company Keller AG/SA
Special features	To ensure the burglar resistance the handle must be removed in locked condition.

Basis

DIN V ENV 1627 : 1999
Windows, doors, shutters –
Burglar resistance – Require-
ments and classification
DIN V ENV 1628 : 1999
DIN V ENV 1629 : 1999
DIN V ENV 1630 : 1999
Test Report 10-000206-PB04-
A01-05-de-01 dated 19.11.2010

Representation



Instruction for use

The present test report serves to demonstrate the burglar resistance.

Validity

The data and results refer solely to the tested and described specimen. The burglar resistance test does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented.

In deviation from the tested design the following size modifications are permitted:
in width +10% and -20%
in height +10% and -20%

Burglar resistance



Resistance class 2

ift Rosenheim
13.09.2012

Robert Krippahl, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Building Components

Günter Borrman, Dipl.-Ing. (FH)
Operating Testing Officer
Mechanics

Notes on publication

The ift-Guidance Sheet „Conditions and Guidance for the Use of ift Test Documents“ applies. The cover sheet can be used as an abstract.

Contents

The report contains a total of 66 pages

- 1 Object
 - 2 Procedure
 - 3 Detailed results
 - 4 Assessment
- Annex 1 (14 pages)
Annex 2 (38 pages)