

Evidence of Performance

Burglar resistance

Test Report

No. 15-001312-PR02

(PB-A01-05-en-03)



Client	Keller AG/SA Route de Wilwerdange 38-40 9911 Troisvierges Luxembourg
Product	Burglar resistant sliding door
Designation	Double leaf sliding door (slide - fix)
Overall dimensions (W x H)	4,197 mm x 2,980 mm
(Frame) Material, System	Aluminium profiles with thermal break, minimal windows®4+
Attack side	Outside of building
Type of opening	Sliding door, scheme A Class A3 as per DIN 52290 Part 4
Glazing	Test report 213 19101 U 2 roller type minimal windows®4+ / company Precom, 2 locking devices (locking bar sleeve) type minimal windows®4+ / company Astec, removable handle type minimal windows®4+ / KELLER AG (turning handle)
Hardware	According to installation instructions from company Keller
Installation	AG/SA
Special features	The handle must be removed in locked condition to ensure the burglar resistant properties.

Basis

DIN EN 1627 : 2011
Doors, windows, curtain walling, grilles and shutters, Burglar resistance - Requirements and classification
DIN EN 1628 : 2011
DIN EN 1629 : 2011
DIN EN 1630 : 2011

Test report 15-001312-PR02 (PB-A01-05-de-03) dated 23.9.2015

Representation



Instructions for use

This test report serves to demonstrate burglar resistance.

Validity

The data and results given refer solely to the tested and described specimen. Testing to burglar resistance does not allow any statement to be made on any further characteristics of the present structure regarding performance and quality

In deviation from the tested type, the following dimensional charges are permitted:
Space A +5% and -20%
space B +5% and -30%
Area +25%

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies.

The cover sheet can be used as an abstract.

Contents

The report contains a total of 51 pages

- 1 Object
 - 2 Procedure
 - 3 Detailed results
- Annex 1 (11 pages)
Annex 2 (3 pages)
Annex 3 (25 pages)

Burglar resistance



RC 2 / RC 2 N

ift Rosenheim
15.10.2015

Robert Krippahl, Dipl.-Ing. (FH)
Operating Product Officer
Building Components

Simon Stuer
Operating Testing Officer
Security/Safety Testing